

Corrigendum-2

Sr. No.	Tender Clause, Page Number	Query/ Description as per tender document	Clarification/ Amendment
1.		What kind of Solar mounting structure is required – Single lag mounted or Double mounted lag structure	Bidder have to meet the required scope and design criteria as per specified standards and seismic load criteria
2.		<p>Clarification / Confirmation needed on Solar plant termination (interconnect solar & grid) point confirmation</p> <p>Please confirm –</p> <ul style="list-style-type: none"> - It must require power termination at the substation or near the 11 kV line as per availability at the site? - Can we use 2 Pole structure and then install ABT/Net Meter on it and connect the line to one grid. - Solar Power Use – As a Net meter or Open Access Power 	The project is to be done on net metering, necessary augmentation of the existing transformers, bus bars etc. or any other electrical infrastructure of the structure in concern shall be in scope of contractor.
3.	3.2.2, Page 27	<p>Bidder shall have an experience of design, supply, installation & Commissioning & Operation & Maintenance of at least 1 MW Solar Power or above in India</p> <p>Clarification need on Experience shown is of Roof top or Ground Mounted</p>	Experience in Ground Mounted Installation shall be considered.
4.	3.2.3, Page 28	<p>The bidder shall submit audited annual report of FY 2012-13, 2013-14, 2014-15 and 2015-16</p> <p>Can last three years of Balance Sheet can be submitted i.e. 2014-15, 2015-16 and 2016-17.</p>	Bidder have to submit audited balance sheet for the last three Financial year from the date of Tender

5.		Geo Technical Report for Solar Plant site location, if available	Download: http://gsdma.org/uploads/Assets/tenders/soilreportofbhujsite02282018101647526..pdf
6.		List of approved Brand – Domestic and International / Origin of Module & Cell	Technical specifications should be met.
7.		Waiver/ Exemption for MSME empanelled with Ministry of New and Renewable Energy on General Pre-requisites like turnover, experience etc, EMD & Tender Fees	As per policy, exemption shall be given only on EMD and Tender fees only, bidder have to furnish required proof
8.		SLD and Roof top drawings	This is a Ground Mounted Structure and bidder shall provide and get approval for Solar panel layout along with its SLD before execution.
9.		The financial bid provided is according to pre GST. Request you to revise according to current taxation.	Bidder to Quote as per the latest taxation structure.
10.	4.14.4, Page 36	Request for relaxation of CUF to 16 %	Clause remain unchanged
11.	4.14.4, Page 36	Clarification requested whether CUF should be considered in DC (MWp) or AC (MW).	CUF should be considered in AC (MW) only
12.	5.1, Page 50	Clarification requested in scope of work on Right of way (R.O.W), bay work, water and Power.	Bidder has to make all the necessary arrangement according to the scope of work provided.
13.		Clarification on set of approval from GSDMA side	All the necessary approval required to set up the 1 MW plant from registration, commissioning and evacuation is in the scope of bidder
14.	7.10, Page 173	Clarification on schedule period for this tender, apart from O&M	Schedule Period for Engineering, Procurement, Construction and Commissioning is 6 months from date of issuance of letter of intent.
15.		Request for estimated cost for the project	Bidder to quote for the same.
16.	Eligibility Clause 3.2.2: Technical Criteria	We request to consider our group company criteria for technical qualification since our parent group have executed more than 600 MW project till now. This amendment is requested to be done in the same way as per Clause No.4.4.2 (q) for financial criteria where	Bidder shall meet the requisite criteria of RFP Clause

		we can use our group company financial documents.	
17.		Permission to submit the documents by 'Hand Delivery'	Clause remain unchanged. Please refer additional points below
18.		Request for due date extension	Refer Corrigendum 1
19.		The EMD value for 1MW is in highside (INR 24 lakhs), request you to kind relax and reduce the EMD Value	Clause remain unchanged
20.		Please relax the clause for OBG for O&M from 10 th year to 5 th year	Clause remain unchanged
21.		Relocation of 11 kV Over Head Line from actual to Near the Boundary line of the Land Area. It is not recommended to install solar power plant near the 11 kV overhead line we would like to recommend you to relocate the overhead line near the ground boundary line	11 kV line must be atleast 20 meters (Linear) away from solar power panel. Relocation would be considered.
22.		Water pipeline lies in-between the area proposed for the solar power plant, so kindly confirm the offset for this Waterline.	Bidder have arrange required buffer (min. 10-15 Meters from pipeline)
23.		As per the terms and conditions of the tender document, the Technical Qualifying conditions requires atleast 1 MW solar power plant in operation for atleast 1 year. Kindly amend it to 6 months as we are already providing	Clause remain unchanged

Additionally,

- Last date and time of On-line (e-tendering) tender/offer submission (the "Bid Submission Deadline") is extended upto **16/03/2018, Friday at 16:00hrs** local time. Proposals may be submitted accordingly
- Last date and time of Physical receipt of all the relevant documents by RPAD or Speed Post or in person only is extended upto **16/03/2018 , Friday at 16:00hrs** local time. Documents may be submitted accordingly
- Opening of Technical Bid (online) will be on **16/03/2018, Friday at 17:00hrs** local time.

All the other terms and conditions remain unchanged.

-S/d-